

# DIVISION 06 - WOOD, PLASTIC AND COMPOSITES

## **06 05 00 Common Work Results for Wood, Plastics, and Composites**

### **Design Standards**

1. Use of structural fire-retardant wood is not allowed.
2. All walls of telecommunications closets shall be constructed to include the following:
  - Walls covered with three-quarter inch A-C grade plywood extending from the floor to eight (8) feet above the finished floor and mounted with the "A" side exposed.
  - Wall surfaces painted with two coats light colored, non-conductive paint.
3. Specify that the designer shall provide samples and specification sheets of all proposed exterior materials made from plastic or phenolic from which a decision to approve or deny use can be made. Coordinate delivery of these samples with the Project Manager. Ensure that the selection of these materials happens concurrently with the selection of other exterior materials such as masonry, roofing, metal work, other building trim.
4. Use pressure treated wood for blocking where moisture may be encountered, such as below grade locations and roof locations.

